



**WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED**

SAMPLE NOT COLLECTED
BY UNIT STAFF

1. Name & Address of Sender: - *Vice-principal, Navyug School, Laxmibai Nagar, New Delhi.*
2. Date of Receiving/Collection: - *13-05-2025*
3. Sample No.: - *3941*
4. Sealed Sample (Yes/No):-

Drinking Water Testing Report
Test - Results

Sr. No	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (mg/l)	TDS (mg/l)	Iron (as Fe) (mg/l)	Chloride (as Cl) (mg/l)	Residual Free Chlorine (mg/l)	Coliform Org. MPN / (100 ml)	E. Coli. MPN / (100 ml)
1.	<i>Drinking water.</i>	<i>5</i>	<i>Agreeable</i>	<i>0.7</i>	<i>7.4</i>	<i>90</i>	<i>125</i>	<i>0.12</i>	<i>28</i>	<i>NIL</i>	<i>NIL</i>	<i>—</i>
2.	/											
3.												
4.												
5.												
BIS : 10500 2012	Acceptable Limits	05 max.	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks:- With respect to above tests, all the above water samples ~~except~~ *can/cannot* be considered fit for drinking purposes. However minimum residual free chlorine 0.2 mg/l should be done to avoid contamination.

Chemist/Lab Technician

Praveen
16/05/25
Lab. Technician/Asstt.

- Note:- 1) water samples will be destroyed after testing unless otherwise specified by party.
2) If the sample is not collected by our WQMU staff, the sender/ party will be responsible for any wrong, incomplete or misleading information given by him.
3) This test report is not valid for any legal proceeding.